



May 24, 2022 – Superintendent’s Report

ADMIN UPDATE:

Utility management is requesting approval of Change Order #5 for the Contract A, Water System Improvements Phase II, Water Plants & Wells Project with Thieneman in the amount of \$67,672.73.

Operational Data:

April Totals

SANITARY SEWER SYSTEM

- (31) Sanitary sewer lift station work orders completed.
- (61) Sanitary sewer grinder pump station work orders completed.
- (3) Sanitary sewer manholes repaired.
- (1) Sanitary sewer force main repaired.
- (9914) LF of sanitary sewer main cleaned.
- (90) LF of sanitary sewer main CCTV'd
- (3) Sanitary sewer pumps rebuilt.
- Cutting and trimming grass as needed at Utility properties.

Water Distribution Underground Maintenance

- (3) Water main breaks repaired.
- (2) Water service line meter pits installed.
- (3) Water service lines repaired.
- (9) Yard restorations completed.
- Maintained all street and sidewalk cuts until final restoration can be made.
- (16) Fire hydrant inspections.
- (108) Water main valves exercised.
- (15) Valve box repairs performed.
- (3) Water main shut outs performed.
- (3) Water line leak investigation performed.
- (33) Inspections for projects performed.

WATER PLANT/WELL ACTIVITY

Fort Harrison Water Plant

- Ongoing coordination with TCI and Wessler Engineering in getting new filter plant operational.
- Testing alarms with Wessler on backup generators.
- Worked with Wessler and TCI to replace flow meter on Well 9.
- Cutting and trimming grass as needed.

Indian Lake Water Plant

- Ongoing coordination with TCI and Wessler Engineering in getting work completed at water plant.
- Worked with National Water to get Well 16 cleaned and get samples.
- Installed conduit and (2) electrical outlets.
- Bastin Logan worked on aerator motor.

- Cutting and trimming grass as needed.

Richardt Water Plant

- Repaired (caulked) leak around hatch at Well House 1.
- Cutting and trimming grass as needed.

Winding Ridge Booster Station

- Worked with Wessler and TCI to switch over to new pump controls and set up SCADA system.
- Cutting and trimming grass as needed.

52nd Street Tower

- Cutting and trimming grass as needed.

Oaklandon Tower

- Cutting and trimming grass as needed.

Water Quality Samples

- 50 water samples were taken from the distribution system and taken to an independent lab for testing.

Miscellaneous

- (2) Water Plant Operators attended the AWWA Conference for continuing education hours.

BUSINESS OFFICE/SERVICE DEPARTMENT

April Totals

- 15144 Active accounts.
- 1507 Work orders completed.

BILLING ADJUSTMENTS:

1. 10212 Applespice Drive – customer is requesting an adjustment for \$2,152.36 in the sewer portion of the bill due to a service line leak. We recommend approval.
2. 4922 Bassett Drive - customer is requesting an adjustment for \$269.24 in the sewer portion of the bill due to a service line leak. We recommend approval.