

CITY OF LAWRENCE, IN
 2021 SANITARY SEWER OVERFLOW REPORT

DATE	LOCATION	VOLUME (GALLONS)	SOURCE	DISCHARGE POINT	RAIN AMT IN PREVIOUS 24 HRS	FINAL DISPOSITION OF DISCHARGE	Cause
3/18/21	46TH & POST ROAD	24,300	MANHOLE	STORM SEWER/BELL'S RUN DRAINAGE DITCH	1.19	STORM SEWER/DRAINAGE DITCH	RAIN
6/30/21	46TH & POST ROAD	5,400	MANHOLE	STORM SEWER/BELL'S RUN DRAINAGE DITCH	1.06	STORM SEWER/DRAINAGE DITCH	RAIN
7/1/21	46TH & POST ROAD	19,350	MANHOLES	STORM SEWER/BELL'S RUN DRAINAGE DITCH	3.14	STORM SEWER/DRAINAGE DITCH	RAIN
9/22/21	46TH & POST ROAD	39,600	MANHOLE	STORM SEWER/BELL'S RUN DRAINAGE DITCH	3.83	STORM SEWER/DRAINAGE DITCH	RAIN
3/18/21	71ST & OAKLANDON RD	9,750	LIFT STATION/WET WELL	GROUND	1.19	DRAINAGE DITCH/INDIAN CREEK	RAIN
4/11/21	INDIAN LAKE BLVD SOUTH DR, EAST OF WINONA DR	4,125	MANHOLE	GROUND	1.11	INDIAN LAKE	BLOCKAGE IN MAIN
10/15/21	54TH & DAVID STREET	1,603	SEWER MAIN	GROUND/BASEMENT BACKUP	1.53	GROUND/BASEMENT	BLOCKAGE IN MAIN
12/17/21	WARE ST & CHURCH ST.		UNK SEWER MAIN	BACKUP IN HOME TOILET/BATH	0.7	HOME	BLOCKAGE IN MAIN

2021 SSO Locations

