

City of Lawrence Indiana  
2023 Sanitary Sewer Overflow Report

Date	Location	Volume (Gallons)	Source	Discharge Point	Rain/Previous 24 hrs.	Final Disposition of Discharge	Cause	
1/26/2023	8829 Fountainview Dr.	250	Manhole	Ground	N/A	Cleared main and treated affected area	Main Blockage	
2/3/2023	7320 E 43rd Street (MH # 06132040)	3,000	Manhole	Open storm ditch	N/A	Cleared main and treated affected area	Main Blockage	
3/3/2023	7103 Oaklandon Road	49,200	Lift Station/ww lid	Ditch	2.24	Cleaned and treated affected area	Rain	
3/3/2023	4601 Post Road	53,300	Manhole	Storm Sewer/Ditch	2.24	Cleaned and treated affected area	Rain	
3/3/2023	8944 E 46th Street	21,320	Manhole	Storm Sewer/Ditch	2.24	Cleaned and treated affected area	Rain	
3/3/2023	5002 Kitley Avenue	32,000	Manhole	Storm Sewer	2.24	Cleaned and treated affected area	Rain	
3/25/2023	4601 Post Road	19,100	Manhole	Storm Sewer/Ditch	1.8	Cleaned and treated affected area	Rain	
3/25/2023	8944 E 46th Street	7640	Manhole	Storm Sewer/Ditch	1.8	Cleaned and treated affected area	Rain	
3/25/2023	7103 Oaklandon Road	15,700	Lift Station/ww lid	Ditch	1.8	Cleaned and treated affected area	Rain	
4/5/2023	7302 Oakland Hills Dr. (MH 30283036)	Unknown	Manhole	Ground	unknown	Cleaned and treated affected area	Unknown	Contacted by resident on 4/5/23-Crew responded immediately. No active SSO upon arrival
8/9/2023	4601 Post Road	19,500	Manhole	Storm Sewer/Ditch	1.14	Cleaned and treated affected area	Rain	
8/9/2023	8944 E 46th Street	19,500	Manhole	Storm Sewer/Ditch	1.14	Cleaned and treated affected area	Rain	